

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:49 am

PWS ID: UTAH06021 **Name:** WOODS CROSS CITY WATER SYSTEM
Legal Contact: WOODS CROSS WATER SYSTEM **Rating:** Approved
 SCOTT S ANDERSON **Rating Date:** 03/11/1980
Address: 1555 S 800 W **Activity Status:** Active
 WOODS CROSS, UT 84087
Phone Number: 801-292-4421
City Served (Area):
County: DAVIS COUNTY
System Type: Community **Last Inv Update:** 02/24/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/07/2010 **Total Dsgn Cap:**
Population: 8,400 **Surveyor:** ROBERT NUNN **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	ANDERSON, SCOTT S		801-292-4421	801-560-6961	sanderson@woodscross.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	2,551
Combined	Unknown	0	258
			2,809 Total Svc Connections

Storage

Total Storage: 7,700,000 GAL **Number of Units:** 6 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST004	2600 S MIDDLE STORAGE	Underground	1,500,000 GAL	Concrete		A	NO
ST005	2600 S NORTH STORAGE	Underground	1,500,000 GAL	Concrete		A	NO
ST006	1600 S 3.1 MG TANK	Underground	3,100,000 GAL	Concrete		A	NO
ST001	1600 S WEST STORAGE	Underground	500,000 GAL	Concrete		A	NO
ST002	1600 S EAST STORAGE	Standpipe	0 GAL	Concrete		I	NO
ST003	2600 S SOUTH STORAGE	Underground	1,100,000 GAL	Concrete		A	NO

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL - #1 (1500S 300W)	Inactive	WL	8	500 GPM		Yes	GW	Other		
WS002	WELL - #2 (720W 1500S)	Inactive	WL	8	280 GPM		Yes	GW	Other		
WS003	UTAH06013 WEBER BASIN \	Active	CC				No	SW	Permanent	1/1 to 12/31	
WS004	WELL 3-1135W 1500S	Active	WL	16	1000 GPM	1,040 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS005	WELL 4-1200W 2250S	Active	WL	16	1800 GPM	1,500 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS006	MILLS PARK EAST WELL	Active	WL	16	1000 GPM	1,000 GPM	Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*